

## Radon Test Report

---

**Test Performed For:**

RTCA  
2 Hayes Street  
Elmsford, NY 10523  
Phone: ( ) -  
Fax: ( ) -

**Test Performed By:**

RTCA  
Nancy Bredhoff  
2 Hayes Street  
Elmsford, NY 10523  
Phone: (914)345-3380

---

**Address Tested:**

RTCA  
Next to Radon Chamber  
2 Hayes Street  
Elmsford, NJ 10523  
( ) -

Level Tested: Unknown  
Test Started: 07/31/06 @ 09:48 AM  
Test Stopped: 08/03/06 @ 10:48 AM  
Device Type: Continuous Monitor  
Test Number: P0002000-14

Average radon level measured  
1.3 pCi/l  
69 total hours in calculation:  
From: 07/31/2006 @ 01:48 PM  
To: 08/03/2006 @ 10:48 AM  
Calculated on 08/03/2006

---

Dear Customer:

The test conducted at the above location indicated an average radon level below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L).

Since radon levels can vary significantly from season to season it is advisable to conduct at least one short-term test during the winter heating season. The EPA recommends retesting if your living patterns change and if you begin occupying a lower level of your home, such as a basement.

All procedures used in generating this report are in accordance with the current EPA protocols for the analysis of radon in air.

Sincerely,

## Radon Test Report

**Test Performed For:**

RTCA  
 2 Hayes Street  
 Elmsford, NY 10523  
 Phone: ( ) -  
 Fax: ( ) -

**Test Performed By:**

RTCA  
 Nancy Bredhoff  
 2 Hayes Street  
 Elmsford, NY 10523  
 Phone: (914)345-3380

**Address Tested:**

RTCA  
 Next to Radon Chamber  
 2 Hayes Street  
 Elmsford, NJ 10523  
 ( ) -

Level Tested: Unknown  
 Test Started: 07/31/06 @ 09:48 AM  
 Test Stopped: 08/03/06 @ 10:48 AM  
 Device Type: Continuous Monitor  
 Test Number: P0002000-14

Average radon level measured  
**1.3 pCi/l**  
 69 total hours in calculation:  
 From: 07/31/2006 @ 01:48 PM  
 To: 08/03/2006 @ 10:48 AM  
 Calculated on 08/03/2006

